TWIN CITY HOSE, INC.

UL CLASSIFIED MH59973

UL U LOOP FLANGE 2"

Lead-Free Flex™



CLASSIFIED C UL US
WATER QUALITY
DRINKING WATER SYSTEM COMPONENT
NSF/ANSI 61, NSF/ANSI 372
MH59973

MATERIALS

#1-2 HOSE & BRAID: T-321 STAINLESS STEEL HOSE WITH 1-LAYER OF T-304 STAINLESS STEEL BRAID

#3 BRAID BAND: T-304 STAINLESS STEEL

#4 END FITTING: CARBON STEEL RAISED FACE SLIP ON FLANGE

#5 ELBOWS: SCH. 40 CARBON STEEL
*12" ID AND LARGER ARE SCHEDULE STANDARD (STD)

QTY	MODEL NUMBER	SIZE	"A" DIM.	"B" DIM.	MAX WRK. PSIG	MAX TEST	@ TEMP.	LATERAL OFFSET	WT. LBS.
	UL-SL200482	2"	14 ½"	21 ¼"	500	750	70°F	2"	19
	UL-SL250482	2 ½"	16 ¾"	23 ½"	400	600	70°F	2"	30
	UL-SL300482	3"	18 ¾"	26 ½"	288	431	70°F	2"	38
	UL-SL400482	4"	24 ¾"	31 ¾"	250	375	70°F	2"	61
	UL-SL500482	5"	30 ¾"	36 ¾"	200	300	70°F	2"	96
	UL-SL600482	6"	36 ¾"	42 ¼"	175	263	70°F	2"	139
	UL-SL800482	8"	48 ¾"	52"	212	318	70°F	2"	280
	UL-SL010482	10"	61"	61 ¾"	175	263	70°F	2"	455
	UL-SL012482	*12"	73"	71"	160	240	70°F	2"	668

TEMPERATURE DERATING FACTORS: MULTIPLY X WRK. PSIG							
200° F	250° F	300° F	350° F	400° F	500° F	600° F	700° F
0.94	0.92	0.88	0.86	0.83	0.78	0.74	0.7

DRAWN BY: _____ DRAWING NUMBER: _____ REV: _____

SIGNATURE: _____ DATE: _____

PO NUMBER: _____ PROJECT: _____

CUSTOMER: _____ NOTES: _____

20615 Commerce Blvd., Rogers, MN 55374 P 1-800-670-9475 F 763-428-5111 E sales@twincityhose.com W www.twincityhose.com